

2017 SB-12 Code Options

Table 3.1.1.2.A (SI)

ZONE 1 - Compliance Packages for Space Heating Equipment with AFUE ≥ 92%
Forming Part of Sentence 3.1.1.2.(1)

Component	Thermal Values	Compliance Package					
		A1	A2	A3	A4	A5	A6
Domestic Hot Water Heater ⁽⁷⁾	Min. EF	0.8	0.7	0.67	0.67	0.8	0.8
Navien Model	EF	A1	A2	A3	A4	A5	A6
NPE-150S	0.99	✓	✓	✓	✓	✓	✓
NPE-180S	0.99	✓	✓	✓	✓	✓	✓
NPE-210S	0.99	✓	✓	✓	✓	✓	✓
NPE-240S	0.99	✓	✓	✓	✓	✓	✓
NPE-180A	0.98	✓	✓	✓	✓	✓	✓
NPE-210A	0.98	✓	✓	✓	✓	✓	✓
NPE-240A	0.98	✓	✓	✓	✓	✓	✓

(7) If an EF of a water tank is not indicated in a compliance package, there is no EF requirement for water tank for that specific compliance package.

For prescriptive path in A4 combo systems, the requirements are as follows:

- a minimum TPF of 0.85
or
- 90% AFUE
or
- a minimum 0.8 EF

All Navien combi systems (**NCB-E** or **NPE** with **H2Air Kit**) meet or exceed

